Salinity in Coastal Trunklines



1

GWRS Final Expansion

- Substantially complete as of early Dec. 2022
 - Completed 90-day performance test
- OC San Plant No. 2 completely segregated
 - Reclaimable
 - Non-reclaimable
- Target
 - 170 MGD reclaimable flow from OC San
 - 130 MGD finished water
- Performance test
 - Higher salinity => higher pressure for RO units => higher cost

2

2018 Estimated Salinity in Plant No. 2 Reclaimable Effluent

P2 TFSC Effluent

Average: 2,400 mg/L total dissolved solid (TDS)

Blend of P2/P1 Flow at 50/120 MGD (P2=29.4%)

- Target: 1,400 mg/L
- Interstage booster pumps installed
- Increase pressure at RO units to remove TDS

3

2018 Plant No. 2 Salinity Survey

P2 Trunklines		Average TDS Concentration (mg/L)
1	Coast (Huntington Beach - coastal)	4,260
2	Newport (coastal)	4,500
3	Miller-Holder (inland)	1,533
4	Bushard (inland)	1,240
5	Interplant (non-reclaimable)	2,300

Seawater TDS: ~33,000 mg/L

4

2023 Preliminary Plant No. 2 Salinity Investigation

P2 TFSC effluent TDS

- Dec. 2022: 3,390 mg/L
- 2018 projected threshold: 2,400 mg/L

Adjusted blend of P2/P1 flow at ~25/145 MGD

- P2 limited to ≤15% of total reclaimable flow
- Decrease from target of 29.4% of total reclaimable flow

.


5

TDS Source Investigation

- Mass balance: TDS x flow
 - GWRS Design Objective: $^{2.2}$ x $^{10^6}$ lbs/d ($^{1.0}$ x $^{10^6}$ kg/d)
- · Trunkline and tributary sampling
 - Snap shot sampling of coastal trunklines
 - Sequential sampling pre- and post- convergence
- Factors
 - Tidal influence on seawater intrusion
 - Wet weather inflow
 - City of Newport Beach tidal valves


6






City of Newport Beach Tidal Valves





9





11

Logistics

- Infrastructure Access
- Personnel
- Equipment
- Laboratory Support/Coordination

12

Collaborating Agencies









13

13

Questions

