

Orange County Sanitation District
 Odor Complaint Report
 Fiscal Year 2020/21 – 4th Quarter

1. Plant No. 1 Treatment Facility Odor Complaint Summary

Plant No. 1 received one attributable odor complaint in the headworks area during the 4th quarter. Urgent maintenance was required for Sunflower influent pump #1. During the repairs, pump covers must be removed which allow foul air to escape. Covers were reinstalled in between maintenance work to minimize odors.

Plant No. 2 Treatment Facility Odor Complaint Summary

Plant No. 2 received one attributable odor complaint during the 4th quarter. Based on wind direction and odors described by the resident, the Plant No. 2 truckloading area was determined the odor source. Truckloading scrubbers were adjusted to reduce odors. In addition, biosolid drivers were reminded to immediately cover trailers once loaded. A future project has been approved that will reduce the fugitive odors in the Plant No. 2 truckloading area.

2. Collections Facilities Odor Complaint Summary

The collection system received no attributable odor complaints during the 4th quarter.

All Odor Complaints Tracking

All Public Complaints	Apr. 2021 to Jul. 2021			1 st Qtr FY 20/21	2 nd Qtr FY 20/21	3 rd Qtr FY 20/21	4 th Qtr FY 20/21	Cumulative FY 20/21
	Collections	P1	P2	Total	Total	Total	Total	Total
Attributable to OC San	0	1	1	6	6	2	2	16
Not Attributable to OC San	4	3	1	4	5	8	8	25
Total Public Complaints Received:	4	4	2	10	11	10	10	41