

# Orange County Sanitation District

## Odor Complaint Report

### Fiscal Year 2022/23 – 2<sup>nd</sup> Quarter

#### 1. Plant No. 1 Treatment Facility Odor Complaint Summary

Plant No. 1 received one attributable odor complaint during the 2<sup>nd</sup> quarter. The odor complaint was due to preventative and corrective maintenance at Sunflower Pump Station. Work was completed, and covers were reinstalled.

#### Plant No. 2 Treatment Facility Odor Complaint Summary

Plant No. 2 received no attributable odor complaints during the 2<sup>nd</sup> quarter.

#### 2. Collections Facilities Odor Complaint Summary

The Collection System received four attributable odor complaints during the 2<sup>nd</sup> quarter. All four complaints were due to the pressurization and ventilation of foul odors escaping sewer manhole covers. The manhole covers have been sealed to reduce sewer odor and prevent further complaints. Two of the odor complaints originated in the City of Huntington Beach. The third complaint originated in the City of Garden Grove, and the fourth complaint originated in the City of Buena Park.

#### All Odor Complaints Tracking

	Oct. 2022 to Dec. 2022			1 <sup>st</sup> Qtr FY 22/23	2 <sup>nd</sup> Qtr FY 22/23	3 <sup>rd</sup> Qtr FY 22/23	4 <sup>th</sup> Qtr FY 22/23	Cumulative FY 22/23
<b>All Public Complaints</b>	<b>Collections</b>	<b>P1</b>	<b>P2</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>
Attributable to OC San	4	1	0	5	5			10
Not Attributable to OC San	5	2	0	14	7			21
Total Public Complaints Received:	9	3	0	19	12			31