

**Orange County Sanitation District
Odor Complaint Report
Fiscal Year 2025/26 – 2nd Quarter**

1. Plant No. 1 Reclamation Facility Odor Complaint Summary

Plant No. 1 received no attributable odor complaints during the 2nd quarter.

2. Plant No. 2 Reclamation Facility Odor Complaint Summary

Plant No. 2 received one attributable odor complaint during the 2nd quarter. The complaint was associated with electrical maintenance activities that resulted in a temporary loss of power to the online truckloading fan and scrubber. The equipment issues were resolved at approximately the same time the complaint was reported, and corrective measures have since been implemented to mitigate future complaints.

3. Collections Facilities Odor Complaint Summary

The Collection System received three attributable odor complaints during the 2nd quarter. The complaints were due to the pressurization and sewer ventilation of foul odors escaping from sewer covers. The manhole covers have been sealed to reduce sewer odor and prevent further complaints. One of the odor complaints originated in the City of Garden Grove, one in Costa Mesa, and one in Huntington Beach.

All Odor Complaints Tracking

All Public Complaints	Oct. 2025 to Dec. 2025			1 st Qtr FY 25/26	2 nd Qtr FY 25/26	3 rd Qtr FY 25/26	4 th Qtr FY 25/26	Cumulative FY 25/26
	Collections	P1	P2	Total	Total	Total	Total	Total
Attributable to OC San	3	0	1	5	4			9
Not Attributable to OC San	3	2	0	15	5			20
Total Public Complaints Received:	6	2	1	20	9			29