

Orange County Sanitation District
 Odor Complaint Report
 Fiscal Year 2021/22 – 1st Quarter

1. Plant No. 1 Treatment Facility Odor Complaint Summary

Plant No. 1 received one attributable odor complaint during the 1st quarter. This odor complaint was caused due to routine maintenance on a collections system air jumper. This air jumper is in the middle of a residential neighborhood near Plant No. 1.

Plant No. 2 Treatment Facility Odor Complaint Summary

Plant No. 2 received no attributable odor complaints during the 1st quarter.

2. Collections Facilities Odor Complaint Summary

The Collection System received one attributable odor complaint during the 1st quarter. The reported odor complaint was due to the pressurization and sewer ventilation of foul odors in the City of Buena Park. The manhole was sealed to reduce sewer odor and prevent any further complaints.

All Odor Complaints Tracking

All Public Complaints	Jul. 2021 to Sep. 2021			1 st Qtr FY 21/22	2 nd Qtr FY 21/22	3 rd Qtr FY 21/22	4 th Qtr FY 21/22	Cumulative FY 21/22
	Collections	P1	P2	Total	Total	Total	Total	Total
Attributable to OC San	1	1	0	2				2
Not Attributable to OC San	3	0	2	5				5
Total Public Complaints Received:	4	1	2	7				7