

Orange County Sanitation District  
 Odor Complaint Report  
 Fiscal Year 2021/22 – 3<sup>rd</sup> Quarter

1. Plant No. 1 Treatment Facility Odor Complaint Summary

Plant No. 1 received two attributable odor complaints during the 3<sup>rd</sup> quarter. The first odor complaint was associated with the headworks bioscrubber pH. The scrubber pH was adjusted to enhance performance. The second odor complaint was associated with headworks scrubber #3. Bleach dosing was increased to mitigate odors.

Plant No. 2 Treatment Facility Odor Complaint Summary

Plant No. 2 received no attributable odor complaints during the 3<sup>rd</sup> quarter.

2. Collections Facilities Odor Complaint Summary

The Collection System received no attributable odor complaints during the 3<sup>rd</sup> quarter.

All Odor Complaints Tracking

All Public Complaints	Jan. 2022 to Mar. 2022			1 <sup>st</sup> Qtr FY 21/22	2 <sup>nd</sup> Qtr FY 21/22	3 <sup>rd</sup> Qtr FY 21/22	4 <sup>th</sup> Qtr FY 21/22	Cumulative FY 21/22
	Collections	P1	P2	Total	Total	Total	Total	Total
Attributable to OC San	0	2	0	2	0	2		4
Not Attributable to OC San	4	5	1	5	6	10		21
<b>Total Public Complaints Received:</b>	<b>4</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>6</b>	<b>12</b>		<b>25</b>