

Orange County Sanitation District
 Odor Complaint Report
 Fiscal Year 2020/21 – 3rd Quarter

1. Plant No. 1 Treatment Facility Odor Complaint Summary

Plant No. 1 received no attributable odor complaints during the 3rd quarter.

Plant No. 2 Treatment Facility Odor Complaint Summary

Plant No. 2 received one attributed odor complaint during the 3rd quarter. The odor complaint was due to odors in the truckloading area. The chemical dosing was adjusted in the truckloading scrubbers for more efficient odor removal.

2. Collections Facilities Odor Complaint Summary

The collection system received one attributable odor complaint during the 3rd quarter. In the City of Costa Mesa, a reported odor complaint was due to the pressurization and sewer ventilation of foul odors during sewer maintenance activities. The manhole was sealed to reduce sewer odor and prevent any further complaints.

All Odor Complaints Tracking

All Public Complaints	Jan. 2021 to Mar. 2021			1 st Qtr FY 20/21	2 nd Qtr FY 20/21	3 rd Qtr FY 20/21	4 th Qtr FY 20/21	Cumulative FY 20/21
	Collections	P1	P2	Total	Total	Total	Total	Total
Attributable to OC San	1	0	1	6	6	2		14
Not Attributable to OC San	2	3	3	4	5	8		17
Total Public Complaints Received:	3	3	4	10	11	10		31