



Process Control Systems Upgrades Study Project No. SP-196 Information Item

Mike Dorman, Engineering Manager
Operations Committee
September 4, 2019




Agenda




Update on where we are since we started Project SP-196, Process Control Systems Upgrades Study




Supervisory Control and Data Acquisition (SCADA)




Pump Level Control



Human Machine Interface



Human Machine Interface



Human Machine Interface



AREA 55

ROCKY POINT CONFIGURATION 1

G_55ROCK_CFG01

OPERATING & ALARM SETPOINTS

LEAD START / STOP LEVELS:

LEAD START (0-190): 86 INCH
LEAD STOP (0-190): 71 INCH

LAG START / STOP SPEED:

LAG1 START (65-90): 90 %
LAG1 STOP (65-90): 65 %
LAG2 START (65-90): 90 %
LAG2 STOP (65-90): 65 %

FORCEMAIN PRESSURE ALARM:

HI HI ALARM (0-50): 50.00 PSI
HI ALARM (0-50): 30.00 PSI
LO ALARM (0-50): 0.00 PSI
LO LO ALARM (0-50): 0.00 PSI

WETWELL LEVEL ALARM:

HI HI ALARM (0-190): 110 INCH
HI ALARM (0-190): 100 INCH
LO ALARM (0-190): 48 INCH
LO LO ALARM (0-190): 36 INCH

LEL ALARM:

HI HI ALARM (0-100): 20 %
HI ALARM (0-100): 10 %

CURRENT
VALUE

PUMP DUTY SEQUENCE SELECTION

| LEAD | LAG1 | LAG2 | STDBY | | SEQ |
|------|------|------|-------|-------------------------------------|-----|
| 1 | 2 | 3 | 4 | <input checked="" type="checkbox"/> | 1 |
| 2 | 3 | 4 | 1 | <input type="checkbox"/> | 2 |
| 3 | 4 | 1 | 2 | <input type="checkbox"/> | 3 |
| 4 | 1 | 2 | 3 | <input type="checkbox"/> | 4 |

EQUIPMENT SERVICE SELECTION

| | IN SERV | OUT SERV |
|-----------------------|-------------------------------------|--------------------------|
| VFD PUMP 1: | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| VFD PUMP 2: | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| VFD PUMP 3: | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| VFD PUMP 4: | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| SONIC 1 LEVEL SENSOR: | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| SONIC 2 LEVEL SENSOR: | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| SUPPLY FAN: | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| EXHAUST FAN: | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

LEVEL SOURCE SELECTION

| | | ACTIVE |
|----------------|-------------|-------------------------------------|
| SONIC 1 LEVEL: | 81.2 IN ALM | <input checked="" type="checkbox"/> |
| SONIC 2 LEVEL: | 81.7 IN ALM | <input type="checkbox"/> |



MENU

GRAPHIC

CONFIGURE

TRENDS

SUMMARY

SEQUENCE

RUNTIME

HELP

Plant 1 Control Center




SCADA system allows 24-hour operation from 1 location at each plant

Why Replace the Human Machine Interface?



- HMI System – CRISP (Process, electrical and pump stations)
 - 100 HMI Workstations
 - ~850 Graphics Screens
 - 33 Servers
 - 25 years old
 - Uses VAX workstation and VAX emulation software
 - OCSD owns the software code
 - Added features over the years to meet our needs
 - CRISP programmers reaching retirement age
- HMI System – Wonderware (Central Generators)



Why Replace the Programmable Logic Controllers?



- PLC – Modicon Quantum

- 150 Networked PLC's
- 25+ Standalone PLC's
- ~44,000 input/output points

- 20 Years Old


- Processors no longer manufactured
- Input/output modules no longer manufactured in the near future

- Maintainability Plan

- Spares in warehouse for replacement and near term future projects (purchased 38 spare processors)
- Using next generation Modicon PLC (M580) for new projects (J-117B)




SP-196 Scope of Work



- Determine Requirements
 - Available SCADA technology
 - System requirements
 - Smart devices and instruments
 - Integration with business and maintenance systems
 - Predictive maintenance
 - Advanced control feature
 - Historian
- Select a Vendor
 - 20-Year agreement (software and hardware)
 - HMI replacement



SCADA System Replacement




- Replace existing HMI software through Project No. J-120 (price included in proposal)
 - Develop new graphic standards
 - Develop new controller programming standards
- Replace controllers as part of future CIP projects over the next 20 years (costs for hardware and programming included in CIP budget)

Our SCADA system replacement project will be easier than other systems:

- **Excellent documentation of our system, programs and standards**
- **Not doing a gut and replacement of the controllers**



SP-196 Key Decision



Programmable Logic Controllers (PLC) versus Distributed Control System (DCS)


| | HMI/PLC System | DCS System |
|---------------|-------------------------------|--------------|
| HMI Software | HMI Vendor | X |
| Controller | PLC Vendor | X |
| Training | HMI and PLC Vendor | X |
| Control Panel | Panel Fabricator | X |
| Programming | In-House / Systems Integrator | In-House / X |

DCS's traditionally more expensive. OCSD elected to compete DCS with HMI/PLC since DCS's are becoming more competitive. DCS offers a more integrated system.

We could have just extended the sole source, but we felt it was important to openly bid for the next 20 years



RFQ/RFP Process



SP-196 Scope of Work



SOQ Proposers

- DCS


- ABB ←
- Emerson ←
- Honeywell

- HMI

- AVEVA – Wonderware ←
- Rockwell Automation
- Trihedral – VTScada



Future Board Action



Future Board Action

1. Approve a 20-year unit-price agreement Master Service Agreement
 1. Software licensing costs
 2. Equipment costs
 3. Programming hourly rates (DCS only)
 4. Control panel costs (DCS only)
2. Award Project J-120





Questions?

