Orange County Sanitation District

Administration Building 10844 Ellis Avenue Fountain Valley, CA 92708 (714) 593-7433



Agenda Report Details (With Text)

File #: 2022-2180 Version: 1 Name:

Type: Information Item Status: Filed

File created: 2/25/2022 In control: OPERATIONS COMMITTEE

On agenda: 4/6/2022 Final action: 4/6/2022

Title: TPAD DIGESTER FACILITY AT PLANT NO. 2, PROJECT NO. P2-128

Sponsors: Kathy Millea

Indexes:

Code sections:

Attachments: 1. Agenda Report, 2. Presentation - P2-128 Info Item

Date Ver. Action By Action Result

4/6/2022 1 OPERATIONS COMMITTEE

FROM: James D. Herberg, General Manager

Originator: Kathy Millea, Director of Engineering

SUBJECT:

TPAD DIGESTER FACILITY AT PLANT NO. 2, PROJECT NO. P2-128

GENERAL MANAGER'S RECOMMENDATION

RECOMMENDATION:

Information Item.

BACKGROUND

Sludge is a byproduct of wastewater treatment that requires further processing to reduce pathogens and volatile organic content so the remaining biosolids material can be beneficially reused in compliance with state and federal requirements. The Orange County Sanitation District (OC San) uses anaerobic digesters at both plants to stabilize sludge prior to dewatering. Anaerobic digesters are large enclosed concrete structures that require pumping, mixing, heating, and gas handling systems. Anaerobic digesters also generate methane gas used to produce power and heat.

OC San has 18 digesters at Plant No. 2 that were built from 1959 through 1979. A comprehensive Biosolids Master Plan completed in 2017 recommended upgrading the existing digester complex by adding Temperature Phased Anaerobic Digestion (TPAD) facilities.

TPAD Digester Facility at Plant No. 2, Project No. P2-128, is the first of four sequential projects planned to ultimately replace the entire digester complex by 2040. The Preliminary Design Report for this \$455 million project was completed in January 2022.

File #: 2022-2180, Version: 1

Staff will present an update on the project and decisions used to control costs.

RELEVANT STANDARDS

- 24/7/365 treatment plant reliability
- Safe, beneficial reuse of Biosolids
- Use all practical and effective means for resource recovery

ATTACHMENT

The following attachment(s) may be viewed on-line at the OC San website (www.ocsan.gov) with the complete agenda package:

Presentation

JM:jw